

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 1452-1631:104

Page 1 of 1

CATEGORY: Floor-to-Floor/Floor-to-Wall Joint Systems

LISTEE: Tremco Inc., 2628 Pearl Rd, Medina OH 44256
Contact: Mason Erwin (866) 209-2404 FAX (330) 220-7055

DESIGN: DYMERIC 511 caulk for use in floor-to-floor and floor-to-wall joint systems in concrete floor joint openings. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	System No	Assembly Rating	Maximum Joint Width
	FF-S-0025	3 & 4 hour	1" inch
	FF-D-0009	2 hour	2" inch
	FF-D-0010	3 & 4 hour	1" inch
	WW-D-0010	3 & 4 hour	1" inch

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, hourly rating, and UL label.

APPROVAL: Listed as firestop caulk for use in floor-to-floor and floor-to-wall joint systems when constructed and installed in accordance with UL Fire Resistive Directory. Approved for UL Systems Design Nos. FF-S-0025, FF-D-0009, FF-D-0010 and WW-D-0010.

05-06-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 30, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**